



FIRE ALARM SYSTEM SUBMITTALS

Information Required for Submittal to be reviewed by FSCI

See NFPA 72 for a complete submittal list.

- Plans must be to a reviewable scale and include a scope of work outlining details of the project.
- Plans must show job name and complete address.
- The square foot area of the building must be noted on the plans.
- A summary sheet or symbol list showing a device count shall be provided.
- Catalog cut sheets must be provided and highlighted for all components to be installed.
- Specific details must be provided regarding the offsite monitoring of the system including type of transmission means and name and location of receiving station.
- All wiring information must be shown on the plans including size, type, and all point-to-point wire runs.
- Complete battery backup calculations must be provided that clearly note battery size to be provided.
- Voltage drop calculations using the "UL MAX" values for notification appliances must be provided.
- All plans must have the contractors name, address, and phone number.

Information Contact:	Pleasant Prairie Fire & Rescue firerescue@pleasantprairiewi.gov 262.694.8027
----------------------	--