

- 1. MECHANICAL JOINTS FROM TEE TO VALVE AND FROM VALVE TO HYDRANT SHALL BE RESTRAINED WITH MEGALUGS AND STAINLESS STEEL BOLTS.
- 2. ALL FASTENERS SHALL BE STAINLESS STEEL.
- 3. HYDRANT EXTENSIONS ARE NOT PERMITTED
- 4. ALL HYDRANTS, EXCLUDING STORZ CONNECTION, SHALL BE FACTORY PAINTED WITH EPOXY AS IDENTIFIED BELOW:
 - A. PUBLIC (VILLAGE) HYDRANTS SHALL BE MUELLER RED SHERWIN WILLIAMS POLANE F63RL15
 - B. PRIVATE HYDRANTS ON VILLAGE SYSTEM PRESSURE SHALL BE CAUTION BLUE SHERWIN WILLIAMS POLANE F63RXL9667
 - C. PRIVATE PRESSURED HYDRANTS ON FIRE LOOPS SHALL BE MUELLER YELLOW SHERWIN WILLIAMS POLANE F63YL14
- 5. REFER TO VILLAGE STANDARD SPECIFICATIONS FOR WATER MAIN CONSTRUCTION

SCALE: NTS

STANDARD HYDRANT ASSEMBLY

DETAIL: W - 1

DATE: 8-19-19

APPROVED BY: MATT FINEOUR

VILLAGE OF PLEASANT PRAIRIE

KENOSHA COUNTY, WISCONSIN