

MECHANICAL JOINTS FROM TEE TO VALVE AND FROM VALVE TO HYDRANT SHALL BE RESTRAINED WITH MEGALUGS AND STAINLESS STEEL BOLTS.

- 2. ALL FASTENERS SHALL BE STAINLESS STEEL.
- REFER TO VILLAGE STANDARD SPECIFICATIONS FOR WATER MAIN CONSTRUCTION.
- 4. HYDRANT SPECIFICATIONS 2 EACH 2-1/2 INCH NST NOZZLE. 1 FACTORY INSTALLED 5-INCH STORZ CONNECTION AND CAP MANUFACTURED BY MUELLER.
- 5. PAINT SPECIFICATION PLEASE REFER TO VS-0400 OF THE VILLAGE CONSTRUCTION SPECIFICATIONS.

SCALE: NTS

6. HYDRANT EXTENSIONS ARE NOT PERMITTED.

STANDARD HYDRANT ASSEMBLY

VILLAGE OF PLEASANT PRAIRIE

DETAIL: W - 1

KENOSHA COUNTY, WISCONSIN APPROVED BY: MATT FINEOUR

DATE: 12-17-18